

OFFICE OF THE ENGINEER -IN-CHIEF  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
MADHYA PRADESH . BHOPAL

No.9607/SE(D)/ENC/PHE

BHOPAL DT.17-12-83

To

- (1) All Superintending Engineers
- (2) All Executive engineers  
Public Health Engg. Deptt

Sub :- Minimum depth of casing pipes in tube well.

from sanitary point of view a minimum depth of 9 m. of casing pipes have to be provided (so that protection of drinking water against sub-surface) pollution can be ensured .

Sd./-  
ENGINEER -IN-CHIEF  
PUBLIC HEALTH ENGG DEPTT  
M . P. Bhopal.

Endt No. 9608/SE(D)/ENC/PHED/

Bhopal dt 17-12-83

copy forwarded to :

1. The Chief Technical Examiner (v) M.P., Bhopal in reference to his letter No. 4605 /CTE(v) / PHE Sugg-2/82-83 M. 6-10-82 and is requested to drop the case .
2. The Chief Engineer (West /East ), P.H.E.D., Bhopal for information and necessary action.

Sd./-  
ENGINEER -IN-CHIEF  
PUBLIC HEALTH ENGG DEPTT  
M . P. Bhopal